rfo-sfps-rajkot@gujarat.gov.in

**FORM B 13.3**

# FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

**(See Rule 25)**

**Fire Safety Certificate Approval (FSCA) No.** FSCA/O/RFORAJ/2024/00065661 **Date:** 01/10/2026
**FSC Safety Certificate Renewal (FSCR) No.** FSCA/O/RFORAJ/2024/00065661/R1

**Building Occupancy/Category:** Educational (non-residential)

To,

Boban Issac
WARD 3/B - adipur GANDHIDHAM GANDHIDHAM Kachchh 370201
**Fire Region:** Rajkot RFO
**Mobile No:** 8511683115 **Email ID:** christschooladipur@gmail.com

We have received Application No.**2026/00189471** dated 29/05/2026 **for Fire Safety Certificate Renewal (FSCR) -** New Building(FSCR)/Existing Building (FSCRe) for the building/premise **KUTCH KELVANI MANDAL CHRIST SCHOOL ADIPUR (name of the Building/ Project)**, as per below mentioned details:

1. **TP Number:**
2. **FP Number:**
3. **Survey Number:** -
4. **Village Name:** GANDHIDHAM
5. **Name of Block(s):** KUTCH KELVANI MANDAL CHRIST SCHOOL ADIPUR

The building/premise was inspected on **01/10/2026** and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on **30/09/2026 11:33:55 AM**
2. Six monthly inspection was done on **18/09/2026 4:30:00 PM**

The Fire Safety Certificate is renewed for a period of **two (2)** years upto **01/10/2028** in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.

This is issued based on the verification and approval of the RFO/CFO dated:**01/10/2026 11:27:32 AM**

**Digitally Verified**
Digitally verified by: Dipen Rajendrabhai Hansora
Fire Safety Officer - General (FSO-G)
2021/001355
Reviewed by : RFO Rajkot
Date: 01/10/2026
Time: 06:42 PM

FSCA/O/RFORAJ/2024/00065661/R1

*This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.*

*Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.*